

TECHNICAL MEMORANDUM

TO:	CITY OF CAMAS
FROM:	MALLORY TAYLOR, P.E.
DATE:	NOVEMBER 20, 2013
SUBJECT:	HYDRAULIC MODEL FIRE FLOW
	RESULTS, GREEN MOUNTAIN
	CITY OF CAMAS, CLARK COUNTY,
	WASHINGTON
	G&O #13493.00

This memorandum discusses the results of running the hydraulic model for fire flow availability for the Green Mountain area. The model was run on November 19, 2013, by Mallory Taylor and the results were checked by Tom Zerkel.

A conceptual water master plan for Green Mountain was added to the Camas hydraulic model to determine available fire flow. The Attachment shows the conceptual master plan for the Green Mountain development.

2015 maximum day demands were applied to the model, with all reservoirs operating and the PRV at Payne Road open and set at 30 psi. The conceptual master plan shows the range of proposed units for the development, which range from 1,524 to 1,779 single-family residential units. Demands were applied to the Green Mountain development based on the Water System Plan ERU value of 296 gpd/ERU. Using the high projection of units for a conservative estimate, the demand for the development totals approximately 527,000 gpd (1,779 units x 296 gpd/ERU). This demand was distributed evenly among the nodes in the new development.

Figure 1 shows the pipe and node ID map for the proposed Green Mountain development. This development will be served off of the 544 Zone through the Lacamas Booster Pump Station (BPS), the Lacamas Reservoir, the 855 Zone through the Payne Road PRV, and Well 9 (when operating).

The highest elevation for the proposed development is Node J4-104 at 500 feet. Per the conceptual plan, this area will be served by a BPS. The BPS was not included in the hydraulic model, and this corresponding node was not considered when looking at pressure drops through the 544 Zone during fire flow conditions.

The following scenarios show the available fire flows during 2015 maximum day demands with the Payne Road PRV open and set at 30 psi.



Technical Memorandum November 20, 2013

SCENARIO 1

Scenario 1 assumes that the development is constructed with 8-inch water mains and no improvements or upgrades to the existing distribution piping. See the attached Figure 2.

TABLE 1

Node	Elevation (feet)	Flow (gpm)	Residual Pressure (psi)	Static Pressure (psi)
J4-101	370	710	20	49
J4-102	290	830	20	84
J4-103	270	1,080	20	83
J4-432	227	1,255	20	111
J-5061	200	980	20	123.2

Scenario 1 Fire Flow Data

SCENARIO 2

Scenario 2 assumes 18-inch extension improvements along Goodwin Road and Ingle Road are made. See the attached Figure 3.

TABLE 2

Scenario 2 Fire Flow Data

N. 1	Elevation	Flow	Residual Pressure	Static Pressure
Node	(feet)	(gpm)	(psi)	(psi)
J4-101	370	850	20	49
J4-102	290	965	20	84
J4-103	270	1,270	20	93
J4-432	227	1,147	20	112
J-5061	200	1,028	20	123



Technical Memorandum November 20, 2013

SCENARIO 3

Scenario 3 assumes the extension improvements along Goodwin Road and Ingle Road are made from Scenario 2, and that portions of the 8-inch line along Goodwin Road and Ingle Road are upsized. See the attached Figure 4.

TABLE 3

	Elevation	Flow	Residual Pressure	Static Pressure
Node	(feet)	(gpm)	(psi)	(psi)
J4-101	370	1,159	20	50
J4-102	290	1,460	20	85
J4-103	270	1,764	20	94
J4-432	227	1,745	20	113
J-5061	200	1,725	20	124

Scenario 3 Fire Flow Data


Scenario 3 meets the minimum fire flow requirements of 1,000 gpm for 60 minutes for single-family residences. Although the hydraulic model shows that an 18-inch transmission main meets residential fire flow requirements below an elevation of 370 feet, the City will want to consider installing a 24-inch transmission main to serve the NUGA and the future Green Mountain Reservoir, per the WSP.

The Department of Health and City standards for water distribution systems are to meet the peak hourly demand of the system while providing a minimum pressure of 30 psi system-wide. Under peak daily demand with a fire flow, the system is designed to maintain a minimum pressure of 20 psi system-wide. Although the peak hourly demand pressure may currently be higher than these standards, the developer must recognize that the City may not provide pressure higher than 30 psi in the future. The developer may design their system for whatever pressure they wish; however, they must recognize and be responsible for conditions when the pressure may be less than currently exists.

ATTACHMENT

GREEN MOUNTAIN CONCEPTUAL MASTER PLAN

GREEN MOUNTAIN CONCEPTUAL MASTER PLAN



TOTAL SITE AREA 281.6 AC

SITE AREA TABLE

R10 ZONE	119.5 AC
R6 ZONE	54.0 AC
MF ZONE	92.8 AC
CC ZONE	15.3 AC (13.2 AC)

TOTAL SITE AREA281.6 AC

DENSITY TABLE

				a an
POD	ACRES	AV LOT SF	DENSITY RANGE	UNITS/LOTS
A	15.4	HD	40-45	616-693
B	12.5	1500	13-15	163-188
C	7.5	2500	10-12	75-90
D	28.4	4000	7.5-9	213-256
E	26.9	5000	6-7	161-188
F	26.3	6000	5-5.5	117-145
G []]	30.9	8000	3.75-4.25	116-131
H	50.0	20,000	1.25-1.75	63-88
TOTALS	197.9 AC			1524-1779

PARK & OPEN SPACE $70.0 \pm AC$

CIRCULATION COMPC	DNENTS
ARTERIAL	antonación y a la managara antonación y a
COLLECTOR	and an and a second
NEIGHBORHOOD CIRCULATOR	
NEIGHBORHOOD CONNECTOR	adara kanga kanga kanga kanga kanga kanga kanga kanya ka
COMMUNITY ENTRIES & ACCESS	SPOINTS $\rightarrow \rightarrow \rightarrow \rightarrow$

CAMAS, WASHINGTON GREEN MOUNTAIN LAND, LLC. 08/12/13

PRELIMINARY WETLAND FILLS

ETLAND E	PARTIAL	2595	SF
ETLAND FF	FULL	4581	SF
ETLAND F	FULL	1300	SF
ETLAND Q	PARTIAL	3850	SF
ETLAND R	FULL	1343	SF
ETLAND BB	FULL	442	SF
ETLAND C	FULL	1202	SF
ETLAND DD	FULL	1743	SF
ew wetlan	D 6	+/-800	SF
OTAL		17,857	SF
WHERE AND A STATE AND A STATE OF	or intervent	ANTO NT TO ATTM	310312

NOTE: ELS TO VERIFY THAT WETLAND N IS OUTSIDE OF FUTURE RIGHT OF WAYS GOODWIN & INGLE

MAN MADE POND FILLS

يحوينا والشنواعين بشرجيه ويوطينهم معرفين فالزمر ومالك وتعاشره				
VETLAND . VETLAND I VETLAND I	I H	FULL FULL FULL	.73 .5	AC AC AC
VETLAND	K	FULL	.85	AC
VETLAND		FULL	1.47	AC
VETLAND I	M	FULL	.85	AC
VETLAND	Q/T	FULL	.5	AC
OTAL			5.05	AC

STREAM CROSSING IMPACTS

TREAN	A CROSSI	NG IMPACTS
3	2948 SF	(BUFFER INCLUDED)
	970 SF	(W/O BUFFER)
1	6619 SF	(BUFFER INCLUDED)
	330 SF	(W/O BUFFER)
OTAL	1300 SF	(W/O BUFFER)
N DECISION OF THE ADDA	2000 (201 (2155) 10	
THER	CROSSIN	G IMPACTS
2	3886 SF	(BUFFER ONLY)
3	6534 SF	(MAN MADE DITCH S)
ote: Buff	er impacts ?	IOT CALCULATED
Ditch C 0.38 ac		B'LOOP CONNECTION
(Contin	nues east, gure 2B)	S LOOP CONTECTION
		-THROUGH ADJACENT NUGA BABINI
		AREA.
4		$\begin{bmatrix} E2\\ R5 \end{bmatrix}$ $\begin{bmatrix} F2\\ R6\\ R6 \end{bmatrix}$ $\begin{bmatrix} 25\\ mbridge$
4 4 AC 7.9 AC	• • •	4.9 AC 29-39 01 4.5 AC 23- 230 MIST
59- 71 UN V 255-200		WELEV 265-265 WELEV 280-305
000		
. Cai	kegory IV Begory IV Becres	Stream N (Type NP)
	Weitend X	
VETLINO V	Category I 0.01 acres	Weitand P Celecony IV
	Manual St.	D24 corres
	100	
\sim		
15	A later	RS BOAC
55		HB-SGUNITS USS-31 Weitend
- Cur		ELEV 255-280 DUNITS DABORD
		270-310
C4 R2.5	Utiliziti Comparity Statement	1000 June 1
re	1	
The second	-An -	//
\$5-	6 cours NT	E GOODWIN RD.
	IV	Ľ GUUDNIN ND.
MAIN	S PER	
MAIN STEM DIP)	PLAN	
STEM	1	
DIP))	
		0 300 600

WESTERN PLANNING ASSOCIATES Land Planning Landscape Architecture PO.BOX 2392 LAKE OSWEGO, OR 97035 503-294-0222 SCALE: AS NOTED DESIGNED BY: WFH DRAWN BY: SH CHECKED BY: WFH DATE: 09/19/13 REVISED: STATE OF WASHINGTON REGISTERED LANDSCAPE ARCHITECT WILLIAM F. HORNING CERTIFICATE NO. 382 PLAN LLC GREEN MOUNTAIN CONCEPTUAL MASTER P GREEN MOUTAIN LAND, WASHINGTON CAMAS, OI 6)

he

COPYRIGHT C 2013 BY WESTERN PLANNING ASSOCIATES, INC. ALL RIGHTS RESERVED



