



Legislation Details

File #:	REP 18-038	Version:	1	Name:	Sewer - Crown View Pump Station
Type:	Informational Report	Status:		Status:	Meeting Item
File created:	1/8/2018	In control:		In control:	CITY COUNCIL WORKSHOP
On agenda:	1/16/2018	Final action:		Final action:	
Title:	<p>Consultant Services Contract Crown View Pump Station Details: The Crown View Pump Station located at 3228 NW Ivy Lane was constructed in 1979 and upgraded in 1997. City staff has concerns regarding the pump station's reliability and pumping capacity. The pump station does not have enough back-up power generation to operate both pumps and the existing control panels are dated. The frequent emergency alarms require calling in staff to work additional hours at the pump station. The City has solicited consultant services from Wallis Engineering to prepare a plan to correct deficiencies, assess options and prepare an upgrade plan. Wallis Engineering has submitted a scope of services in the amount of \$77,572.00. This project was anticipated in the 2017/2018 Water/Sewer professional services budget. Presenter: Sam Adams, Utilities Manager</p>				

Sponsors:

Indexes:

Code sections:

Attachments: 1. Consultant Services for the Crown View Pump Station

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------