



Legislation Text

File #: REP 18-038, **Version:** 1

Consultant Services Contract Crown View Pump Station

Details: The Crown View Pump Station located at 3228 NW Ivy Lane was constructed in 1979 and upgraded in 1997. City staff has concerns regarding the pump station's reliability and pumping capacity. The pump station does not have enough back-up power generation to operate both pumps and the existing control panels are dated. The frequent emergency alarms require calling in staff to work additional hours at the pump station. The City has solicited consultant services from Wallis Engineering to prepare a plan to correct deficiencies, assess options and prepare an upgrade plan. Wallis Engineering has submitted a scope of services in the amount of \$77,572.00. This project was anticipated in the 2017/2018 Water/Sewer professional services budget.

Presenter: Sam Adams, Utilities Manager

Recommended Action: Staff recommends this item be placed on the February 5, 2018 Consent Agenda for Council's consideration.